



# Brandweer en Rampenbestrijding Eilandgebied St. Maarten

## Hose reels

**This document contains the technical requirements for Hose reels.**





# Brandweer en Rampenbestrijding

## Eilandgebied St. Maarten

### Requirements for Hose reels

#### Hose reels

- As the total building surface exceeds 250 m<sup>2</sup> hose reels (EN 67-1) must be installed. The number of hose reels is determined in such a manner that a fire in every location in the building can be extinguished.
- The hose must be non-foldable. A hose reel must be hooked up to the regular water supply system.
- The maximum hose length is 30 meters.
- The static pressure at the mouth piece must be 100 kPa and the capacity must be about 1.3 m<sup>3</sup>/hour.

#### Fire Hose reel En 67-1

	<p><u>Fire Hose reel NEN 67-1</u></p> <p>Size of cabinet: 600 x 900 x 255 mm          Diameter 600 mm          Length of the fire hose: 30 meter          Diameter Fire hose 19 mm or ¾ inch.          (for every brand different sizes)</p>
	<p><u>Fire Hose Reel in Cabinet</u></p> <p>Size of cabinet: 900 x 900 x 300 mm          (for every brand different sizes)</p>